


ORDER 9874331

\*\*\*\*\*

UNPLANNED MAINT. <InternalOrderSettle.>



BUS2007-000009874331-PRD

Order	9874331	Ord.type	PM06	
Sup. Order		Act.type	P03	
Planning grp	H80	M.Plan		
Priority	1	Item		Main WC MECHAPSM
STATUS	REL ESTC GMPS NMAT PRC SETC			
Description	BORD. STAB. PRESS. REG. LEAKING			

DUE DATE 11/25/2013

Func. Loc.	HZ-T0-EGF-A069254	Location
	BORDOVSKY STABILIZER	Room
	OCC/TRRC Number	
	Field Name	
	Meter ID Number	
Equipment		Cost Center A069254
		ABC ind.
	Begin Guarantee	
	Warranty End	

Sort Field  
 Manufacturer :  
 Manuf. Serial no:  
 Model no :  
 Technical ID no:  
 Size/Dimension :

### Operation list

Op	Sub	Description	Workcenter
		BORD. STAB. PRESS. REG. LEAKING	
		11/25/2013 13:46:09 Cromwell Campbell III (CROMWC) Phone 1 281-552-6760	
		Flanged pressure regulator #14502C on 2nd cut of fuel gas skid is leaking from vent.	
		Closed in & using bypass line until repairs can be made. Range of regulator is	
		200-275. Re-build kit will be needed.	
0010		BORD. STAB. PRESS. REG. LEAKING	MECHAPSM
		BORD. STAB. PRESS. REG. LEAKING	
		Flanged pressure regulator #14502C on 2nd cut of fuel gas skid is leaking from vent.	
		Closed in & using bypass line until repairs can be made. Range of regulator is	
		200-275. Re-build kit will be needed.	
0020		(DITROL) LABOR	MECHAPSM
0030		(DLS) LABOR	MECHAPSM
0040		(PAC) LABOR	MECHAPSM